



DIVISION OF INDUSTRY SERVICES  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

April 5, 2011 **RE-ISSUED March 26, 2014**

HUFFCUTT CONCRETE, INC.  
BILL OLSON  
4154 123RD ST  
CHIPPEWA FALLS WI 54729

Re: Description: SEWAGE TANKS, RV TRANSFER TANK  
Manufacturer: HUFFCUTT CONCRETE, INC.  
Product Name: RV TRANSFER CONTAINER  
Model Number(s): 375  
(96 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS = 62 IN. DIA.)  
Product File No: 20110080

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of April 2016.**

This approval supersedes the approval issued on 4/19/2010 under product file number 20050912.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only receive waste from recreational vehicles.
- The joints between the tank cover and the inlets and outlet fittings must be made airtight.
- The Zabel filter may only be installed on the outlet of the septic tank.
- When this tank is installed to receive wastewater from only recreational vehicles, the tank must be installed by either a licensed plumber or a holder of a servicing license issued pursuant to s. 145.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code. All servicing and disposal of the contents from these tanks must be in accord with s. 145.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code.

**RE-ISSUED 3/26/14 TO CORRECT THE STIPULATION ABOVE; CHANGE 146.20 TO READ 145.20.**

- This product may only be used as a POWTS holding component in campgrounds permitted by the Department of Health Services under ch. DHS 178 or properties where the use of the camping unit transfer container is permitted by an adopted governmental unit ordinance and monitored by the governmental unit.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov